



CERTIFICATE OF CONFORMITY

Kaustubha Udyog (Orion Instruments), Pune, India

Head Office:

Kaustubha Udyog Pune, India
7, Parichaya Society,
1000 / 6 D, Navi Peth,
Pune: 411 030
Maharashtra, India
Phone: +91-20-24532124
E-mail: ku.pressure@gmail.com

Factory:

Kaustubha Udyog Pune, India
S.No.36/1/1, Sinhagad Road,
Vadgaon khurd
Pune 411041
Maharashtra, India
Phone: +91-20-24393877
E-mail: ku.pressure@gmail.com

Certify that the equipment,

Model FC Series Flameproof Switches (Brand Orion Instruments) with variants viz. Pressure Switches, Pressure Difference Switches, Vacuum Switches and Temperature switches', Catalogue Bulletin No. KA231020

to which this certificate relates, are in conformity with the requirements of the standard **IS/IEC 60079-0:2017, IS/IEC 60079-1:2014** and additional standards as mentioned in Clause 1 of this standard, as applicable.

Marking: Ex db IIC T6 Gb (-20°C ≤ Ta ≤ +60°C) IP66

KLPL Type Examination Report No.: KLPL/Ex/10-006X Issue No.01 Dt.21/09/2022
BIS Licence No.: 0007775906
PESO Approval No. : A/P/HQ/MH/104/7752 (P554640)

We are also having Quality Management System certification to ISO 9001:2015 (Amd.1:2024) standard which ensures the consistent product quality.

Name: Mr. Ravi Moholkar
Position: CEO
For & on behalf of
Kaustubha Udyog Pune, India
Date: 05/03/2025



Doc.No.: KU/FC/CoC

Kaustubha Udyog (Orion Instruments)

Registered Office :

7, Parichaya Society, 1000/6D, Navi Peth,
Pune 411 030. INDIA

Tel.: +91-(0) 20-24532124 / 24531053

Telefax : +91-(0) 20-25460486 / 24532124

Marketing Office :

S. No. 36/1/1, Sinhgad Road, Vadgaon Khurd,
Pune 411 068. INDIA

Tel.: +91-(0) 20-24393577 / 24391592

Telefax : +91-(0) 20-24393577 / 25460486



ISO 9001:2015

Certificate No.: **FM 72815**

Email : ku.pressure@gmail.com / info@orion-instruments.io

Website : www.orion-instruments.io